



Drinking Water Analysis Report

NELAP #E861173 / EPA Lab Code #FL01308

Prepared for: Doc Shane PriorityLab Client Account Phone: (888) 854-0478

Email:

docshane@prioritylab.com

Test Address: Test Client Lab COC #:

52661672

7727 Elm

Miami, FL 12345

Date Collected: 02/19/23 Receive Date:

02/20/23

Analysis Date: 02/20/23 Report Date: 02/20/23

CONCLUSION: Your drinking water FAILED some or all of the Environmental Protection Agency's (EPA) established Primary (health-related) Drinking Water Standards for human consumption. These primary standards must be met for water potability required by FHA/HUD/VA/USDA.

Sample Location: FHA WATER

Tested Contaminant	Results	Acceptable Range	Determination
E. coli bacteria	PRESENT	Zero	FAIL
Coliform bacteria	PRESENT	Zero	FAIL
Lead	20 ppb	0 to 14.99 ppb	FAIL
Nitrate as Nitrogen	0.2 ppm	0 to 10 ppm	PASS
Nitrite as Nitrogen	0 ppm	0 to 1 ppm	PASS

Approved by: John D. Shane Ph.D., Laboratory Manager

In D. Share

The Environmental Protection Agency (EPA) is responsible for the National Primary Drinking Water Regulations (national primary regulations). These regulations are health-related standards that establish the Maximum Contaminant Levels in drinking water. However, the EPA does not regulate private drinking water wells or private water supplies. These water sources are not subject to EPA standards. Some state or local governments do set rules to protect users of these types of water supplies. It is the responsibility of the homeowner to maintain the safety of their water. Information to help homeowners care for their private wells and protect their health can be found at epa.gov/privatewells.

3301 NW 55th Street, Ft. Lauderdale, FL 33309 Tel: (888) 854-0477